

Missouri Department of Natural Resources



PUBLIC NOTICE

DRAFT MISSOURI STATE OPERATING PERMIT

DATE: August 25, 2006

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the Department of Natural Resources, St. Louis Regional Office, 7545 South Lindbergh, Suite 210, St. Louis, Missouri 63125, ATTN: Thomas M. Siegel, Chief, Permits and Engineering. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curd v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by **September 25, 2006** or received in our office by 5:00 p.m. on **September 28, 2006**. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at DNR's website, <http://www.dnr.mo.gov/env/wpp/wpcp-pn.htm>, or at the Department of Natural Resources, St. Louis Regional Office, 7545 S. Lindbergh, Suite 210, St. Louis, Missouri 63125, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: August 25, 2006
Permit Number: MO-0087661
St. Louis Regional Office

FACILITY NAME AND ADDRESS	NAME AND ADDRESS OF OWNER
Camp MO-VAL 2659 Camp MO-VAL RD. Union, MO 63084	Missouri Mid-South Conference United Church of Christ 411 E. Lockwood Ave. St. Louis, MO 63119
RECEIVING STREAM & LEGAL DESCRIPTION	TYPE OF DISCHARGE
Wet Weather Tributary to Bachelor Creek SW1/4,NW1/4,NE1/4 Sec. 7, T42N, R1W, Franklin County	Domestic, reissuance

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0087661

Owner: Missouri Mid-South Conference United Church of Christ
Address: 411 East Lockwood Avenue, St. Louis, MO 63119

Continuing Authority: Same as above
Address: Same as above

Facility Name: Camp MO-Val
Facility Address: 2659 MO-Val Road, Union, MO 63084

Legal Description: SW ¼, NW ¼, NE ¼, Sec. 7, T42N, R1W, Franklin County
Latitude/Longitude: +3824244/-09104271

Receiving Stream: Tributary to Bachelor Creek AKA Roth Creek (U)
First Classified Stream and ID: Bachelor Creek (C)(02035)
USGS Basin & Sub-watershed No.: (07140103-100001)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - Private Campground - SIC #4952 & 7033
Single cell lagoon/facultative lagoon/sludge is retained in lagoon.
Design population equivalent is 38.
Design flow is 3,800 gallons per day.
Actual flow is 950 gallons per day.
Design sludge production is 0.57 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date

Doyle Childers, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

Expiration Date
MO 780-0041 (10-93)

Mike Struckhoff, Director, St. Louis Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS				PAGE NUMBER 2 of 4		
				PERMIT NUMBER MO-0087661		
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001(Note one)</u>						
Flow	MGD	*		*	once/quarter**	24 hr. total
Biochemical Oxygen Demand ₅	mg/L		65	45	once/quarter**	grab/24 hr.
Total Suspended Solids	mg/L		120	80	once/quarter**	grab/24 hr.
pH – Units	SU	***		***	once/quarter**	grab
Ammonia as N	mg/L	*		*	once/quarter**	grab
Temperature	°C	*		*	once/quarter**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, & III</u> STANDARD CONDITIONS DATED October 1, 1980 and August 15, 1994, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** Sample once per quarter in the months of March, June, September, and December.
- *** pH is measured in pH units and is not to be averaged. The pH is to be maintained at or above 6.0pH Units.

Note one- No water quality review sheet was reviewed for this facility.

Comment [CBG3]: Frequency depends on receiving stream and design flow (10 CSR 20-7.015). For most streams, one sample for every 50,000 gallons per year is required. So a 2.6 MGD facility discharging to the Gasconade would require 52 samples a year, or once/week sampling.

Comment [CBG4]: Lagoons may do grabs, mechanical facilities must do 24 hr. composite (10 CSR 20-7.015(8)(C)3.)

Comment [CBG5]:

Comment [CBG6]: Lagoons may do grabs, mechanical facilities must do 24 hr. composite (10 CSR 20-7.015(8)(C)3.)

Comment [CBG7]:

Comment [CBG1]: Select appropriate pH limits below table

Comment [CBG2]: Select appropriate pH limits below table

D. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to area-wide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrylonitrile and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 5-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
5. Report as no-discharge when a discharge does not occur during the report period.
 6. Water Quality Standards
 - (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
 - (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

D. SPECIAL CONDITIONS (continued)

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.
8. The permittee shall comply with any applicable requirements listed in 10 CSR 20-8 and 10 CSR 20-9. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. If a modification of the monitoring frequencies listed in 10 CSR 20-9 is needed, the permittee shall submit a written request to the department for review and, if deemed necessary, approval.
9. The permittee shall submit a report semi-annually in April and October with the Discharge and Monitoring reports which address measures taken to locate and eliminate sources of infiltration and inflow into the City's collection system.

Comment [CBG8]: If they have WET tests, insert the appropriate language from the T:\New Library

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT
FACT SHEET**

This Fact Sheet explains the applicable regulations, rationale for development of this permit and the public participation process.

NPDES PERMIT NUMBER: MO-0087661

FACILITY NAME: Camp MO-VAL

OWNER NAME: 2659 MO-VAL Road, Union MO 63084

LOCATION: SW¼, NW¼, NE¼, Sec 7, T42N, R1W; Franklin County:

RECEIVING STREAM: Tributary to Bachelor Creek

FACILITY CONTACT PERSON: William Kruel TELEPHONE: (636) 583-0052

FACILITY DESCRIPTION AND RATIONALE

This facility is consist of a single cell facultative lagoon. The sludge is retained in the lagoon. The discharge is to a tributary to Bachelor Creek, an unclassified stream. The discharge travels less than 1 1/4 miles to reach a stream segment of Bachelor Creek, which is, classified (class C). The contaminates in this case are BOD₅ and NVSS. The design flow is 3,800 gallons per day and the actual flow is around 950 gallons per day. The submitted discharge monitoring reports were in compliance with the permit limits. Standard technology-based limits for BOD₅, TSS and pH as specified in 10 CSR 20-7.015(8) are believed adequate to protect the receiving stream. Ammonia and temperature have been added as monitoring requirements to determine if there is "reasonable potential" to violate state water quality standards for those parameters. The permit should contain a "reopener clause" should the data generated by this permit, or other monitoring data, indicate that state water quality standards are being exceeded, due at least in part, to this discharge. No water quality review sheet was prepared for this facility.

This permit will be issued for a period of five years.

MAP

